

## STORM WATER DISCHARGE STANDARDS

### Standards for Applicable Discharges not from a Special Waste Facility to Storm Sewer or Direct to False Creek

Parameter	Maximum Concentration (mg/l)
<b>Physical</b>	
pH	6.5 - 8.5
Total Suspended Solids	20.0*
<b>Inorganics</b>	
Aluminum (dissolved)	0.5
Ammonia (total, expressed as nitrogen)	15.0
Arsenic (dissolved)	0.1
Barium (dissolved)	1.0
Boron (dissolved)	10.0
Cadmium (dissolved)	0.05
Chromium (total)	0.5
Cobalt (dissolved)	0.1
Copper (dissolved)	0.1
Cyanide (weak acid dissociable)	0.1
Lead (dissolved)	0.1
Mercury (total)	0.001
Molybdenum (dissolved)	0.5
Nickel (dissolved)	0.5
Tin (dissolved)	0.5
Zinc (dissolved)	0.2
<b>Organics</b>	
Oil & Grease	10.0

\*Standard is 60.0 mg/l for excavation and dewatering operations.

